



**TOWN OF SURFSIDE**  
**Office of the Town Manager**  
MUNICIPAL BUILDING  
9293 HARDING AVENUE  
SURFSIDE, FLORIDA 33154-3009  
Telephone (305) 861-4863

**LETTER TO COMMISSION**

No.: 110-2025

To: Mayor Charles W. Burkett, Vice Mayor Tina Paul, and  
Members of the Town Commission

From: Mark Blumstein, Town Manager *MB*

Date: March 24, 2025

Subject: **Surfside Building Department – Plan Reviews Activity Report**

---

The purpose of this Letter to Commission (LTC) is to transmit the attached Plan Review Activity Report for the period March 17 to March 22, 2025.

This Report highlights the **77** total reviews performed by reviewer as follows:

- *Building/Structural* by Daniel Dominguez – 15 reviews;
- *Flood Review* by Erica Valdes – 2 reviews;
- *Building/Structural* by Ulises Fernandez – 10 reviews;
- *Electrical* by Candelario Martinez – 14 reviews;
- *Mechanical* by Jan Perez – 4 reviews;
- *Planning/Zoning* by Scarlet Hammons – 11 reviews;
- *Plumbing* by Roberto Conde – 13 reviews;
- *Roofing* by Ulises Fernandez – 2 reviews; and
- *Structural/Multi-Family* by Chrome Engineering – 6 reviews.

I trust you will find this Report informative and insightful to better understand how our Town Building Department staff serves the Town and its residents and businesses.

*If you have any questions or need additional information, feel free to contact me.*

Enclosed: Surfside Building Department – Review Activity Report (March 17 – March 22, 2025)



## ALL REVIEWS BY DUE DATE BY DEPARTMENT (03/17/2025 TO 03/22/2025) FOR TOWN OF SURFSIDE

Reviewer	Permit Number /Plan Number	Address	Submittal	Review	Review Status	Version	Required	Complete Date	Assigned Date	Due Date
<b>BUILDING</b>										
DANIEL DOMINGUEZ										
Permit Reviews	2024-006572-BC	8925 Collins Ave FI 33154	Building Review (Commercial)	Building	In Review	2*	Yes		03/07/2025	03/21/2025
	2024-006592-BC	9595 Collins Ave FI 33154	Building Review (Commercial)	Building	Approved	2*	Yes	03/05/2025	03/05/2025	03/19/2025
	2024-006634	9487 Harding Ave	Sign Review	Building	Approved	2*	Yes	03/12/2025		03/19/2025
	2024-006691-BR	9072 Emerson Ave FI 33154	Building Review (Residential)	Building	Approved	3*	Yes	03/12/2025	03/05/2025	03/19/2025
	2025-006930-BR	9148 Carlyle Ave FI 33154	Building Review (Residential)	Building	In Review	1	Yes		02/25/2025	03/18/2025
	2025-007000-BC	9273 Collins Ave FI 33154	Building Review (Commercial)	Building	Approved	1	Yes	02/25/2025	02/25/2025	03/18/2025
	2025-007010-BR	9009 Byron Ave FI 33154	Building Review (Residential)	Building	Approved	2*	Yes	03/13/2025	03/05/2025	03/19/2025
	2025-007024-BR	301 88Th St FI 33154	Building Review (Residential)	Building	Approved	2*	Yes	03/12/2025	03/03/2025	03/17/2025
	2025-007072-BC	9429 Harding Ave FI 33154	Building Review (Commercial)	Building	Requires Re-submit	1	Yes	02/27/2025	02/24/2025	03/17/2025
					<i>Comments: 1. NEED ZONING APPROVAL. 2. PLEASE SUBMIT PROOF OF PERMIT FOR ORIGINAL CANOPY. 3. PLEASE SUBMIT SURVEY TO SHOW LOCATION AND SIZE OF CANOPY WHERE THE FABRIC IS BEING REPLACED.</i>					
	2025-007077-BR	9341 Bay Dr FI 33154	Building Review (Residential)	Building	Approved	1	Yes	02/27/2025	02/25/2025	03/18/2025
	2025-007079-BR	9456 Abbott Ave FI 33154	Building Review (Residential)	Building	Approved	1	Yes	02/27/2025	02/25/2025	03/18/2025
	2025-007084-BR	1380 Biscaya Dr FI 33154	Building Review (Residential)	Building	Approved	1	Yes	03/13/2025	02/26/2025	03/19/2025
	2025-007089-BR	1400 Biscaya Dr FI 33154	Building Review (Residential)	Building	Requires Re-submit	1	Yes	03/13/2025	02/26/2025	03/19/2025
					<i>Comments: DATE: 03.13.2025 PLANS EXAMINER: DANIEL DOMINGUEZ ADDRESS: 1400 BISCAYA DR. PERMIT: 25-7089 PLANS REVIEW DENIED: 1- ADDRESS ZONING COMMENTS 2- PENDING STRUCTURAL ENGINEER REVIEW</i>					
	2025-007104-BC	9201 Collins Ave FI 33154	Building Review (Commercial)	Building	Approved	1	Yes	03/13/2025	02/28/2025	03/21/2025
	2025-007105-BR	9009 Byron Ave FI 33154								

## ALL REVIEWS BY DUE DATE BY DEPARTMENT (03/17/2025 TO 03/22/2025)

Reviewer	Permit Number /Plan Number	Address	Submittal	Review	Review Status	Version	Required	Complete Date	Assigned Date	Due Date
			Building Review (Residential)	Building	Approved	1	Yes	03/13/2025	02/28/2025	03/21/2025
<b>TOTAL REVIEWS FOR DANIEL DOMINGUEZ: 15</b>										
<b>ERICA VALDES</b>										
Permit Reviews	2024-006747-BR	8841 Garland Ave FI 33154	Building Review (Residential)	Flood	Requires Re-submit	2*	Yes	03/04/2025	03/03/2025	03/17/2025
				<p><i>Comments: Good evening,</i></p> <p><i>This permit remains disapproved with same previous comments that have NOT been address/corrected</i></p> <p><i>Private Appraisal is not current. (expired)</i></p> <p><i>Elevation Certificate missing:</i></p> <p><i>C2</i></p> <p><i>G5, G8, G11</i></p> <p><i>Comment section of E.C missing High/Low of Back of Sidewalk and High/Low Crown of Road (identify all roads abutting).</i></p> <p><i>Missing Permit application with construction value.</i></p>						
	2025-006930-BR	9148 Carlyle Ave FI 33154	Building Review (Residential)	Flood	Approved	1	Yes	03/06/2025	02/25/2025	03/18/2025
<b>TOTAL REVIEWS FOR ERICA VALDES: 2</b>										
<b>ULISES FERNANDEZ</b>										
Permit Reviews	2024-006604	9273 Byron Ave FI 33154	Pool Review	Building	Pending Assignment	2*	Yes		03/14/2025	03/21/2025
	2024-006747-BR	8841 Garland Ave FI 33154	Building Review (Residential)	Building	Requires Re-submit	2*	Yes	03/13/2025	03/03/2025	03/17/2025
				<p><i>Comments: 1. PLEASE SUBMIT SURVEY WITH ELEVATIONS OF FINISH FLOOR, EXISTING GRADE, SIDEWALK AND CROWN OF ROAD.</i></p> <p><i>2. PLEASE PROVIDE PROPER SIGN AND SEALED PLANS.</i></p> <p><i>3. PLEASE PROVIDE AN INDEX OF DRAWINGS TO INCLUDE ALL SHEETS ON SET.</i></p> <p><i>4. PLEASE INCLUDE ALL APPLICABLE ELEVATIONS ON SITE PLAN. (SEE COMMENT #1).</i></p> <p><i>5. PLEASE SHOW ALL SERVICE LINES ON SITE PLAN.</i></p> <p><i>6. PLEASE SHOW MINIMUM REQUIRED SHOWER ACCESS.</i></p> <p><i>7. PLEASE SUBMIT ALL PRODUCT APPROVAL FOR ALL HURRICANE STRAPS, HANGERS, CLIPS, ETC.</i></p>						
	2025-006882-BR	8835 Byron Ave FI 33154	Building Review (Residential)	Building	Requires Re-submit	2*	Yes	03/13/2025	03/07/2025	03/21/2025
				<i>Comments: PLEASE SHOW COMPLIANCE WITH THE HVHZ</i>						
	2025-006969	9132 Dickens Ave FI 33154	Building Review (Residential)	Building	Approved	1	Yes	02/28/2025	02/28/2025	03/21/2025
	2025-007024-BR	301 88Th St FI 33154	Building Review (Residential)	Building	Requires Re-submit	1	Yes	02/27/2025	02/25/2025	03/18/2025

## ALL REVIEWS BY DUE DATE BY DEPARTMENT (03/17/2025 TO 03/22/2025)

Reviewer	Permit Number /Plan Number	Address	Submittal	Review	Review Status	Version	Required	Complete Date	Assigned Date	Due Date
				<i>Comments: 1. PLEASE CLARIFY SCOPE OF WORK TO MATCH WITH PERMIT APPLICATION.                      2. IF THIS IS A SUB-PERMIT FOR WINDOWS/DOORS PLEASE INDICATE SO ON PERMIT APPLICATION AND ONLY SUBMIT PLANS WHICH SPECIFY THE WINDOW/DOOR SCOPE OF WORK. (PLANS PROVIDED SHOW DEMOLITION WORK AS WELL?)                      3. IF THIS IS A REVISION, PLEASE PROVIDE A BRIEF DESCRIPTION ON APPLICATION AND CLOUD ALL CHANGES ON PLANS. ALSO, IF THIS IS A REVISION SUBMIT ORIGINAL JOB COPY TO REFERENCE THE EXISTING APPROVED CONDITIONS.</i>						
	2025-007035-BC	9481 Harding Ave FI 33154	Building Review (Commercial)	Building	Pending Assignment	1	Yes		02/25/2025	03/18/2025
	2025-007088	724 90 St FI 33154	Building Review (Residential)	Building	In Review	1	Yes		02/26/2025	03/19/2025
	2025-007094	524 89 St FI 33154	Building Review (Commercial)	Building	In Review	1	Yes		02/27/2025	03/20/2025
	2025-007096	9133 Collins Ave FI 33154	Building Review (Commercial)	Building	Approved	1	Yes	02/27/2025	02/27/2025	03/20/2025
	DEMO-2025-006973	9450 Bay Dr FI 33154	Demolition Review	Building	Approved	2*	Yes	03/03/2025	03/03/2025	03/17/2025

**TOTAL REVIEWS FOR ULISES FERNANDEZ: 10**

**TOTAL REVIEWS FOR BUILDING: 27**

### ELECTRICAL

#### CANDELARIO MARTINEZ

Permit Reviews	2023-004686	8855 Collins Ave FI 33154	Electrical Trade Review	Electrical	Approved	1	Yes	02/27/2025	02/26/2025	03/19/2025
	2024-006604	9273 Byron Ave FI 33154	Pool Review	Electrical	Pending Assignment	2*	Yes		03/14/2025	03/21/2025
	2024-006615	9073 Dickens Ave FI 33154	Electrical Trade Review	Electrical	Approved	2*	Yes	03/05/2025	03/04/2025	03/18/2025
	2024-006723	300 Surfside Blvd FI 33154	Pool Review	Electrical	Pending Assignment	1	Yes		03/04/2025	03/18/2025
	2025-006930-BR	9148 Carlyle Ave FI 33154	Building Review (Residential)	Electrical	Requires Re-submit	1	Yes	02/26/2025	02/25/2025	03/18/2025
				<i>Comments: 1. Please show on plans the FPL letter with the transformer fault information as well as the AIC calculation.                      2. It appears that the exterior open air trellis is a wet location. Please clearly identify the area as a wet location an note that all conduits, conductors, boxes, lights, fans, devices, etc., must be listed for wet locations.</i>						
	2025-007037-Comm	9485 Harding Ave FI 33154	Electrical Trade Review	Electrical	Approved	2*	Yes	03/11/2025	03/06/2025	03/20/2025
	2025-007058	1420 Biscaya Dr FI 33154	Electrical Trade Review	Electrical	In Review	1	Yes		02/25/2025	03/18/2025
				<i>Comments: Needs building inspector to review.</i>						
	2025-007076-Comm	9595 Collins FI 33154	Electrical Trade Review	Electrical	Requires Re-submit	1	Yes	03/04/2025	02/27/2025	03/20/2025
				<i>Comments: 1. Is there a related master permit# for other work (roofing, etc.).                      2. Need plans or more specifics on permit description. What type of disconnects, amps, how many, etc.</i>						
	2025-007089-BR	1400 Biscaya Dr FI 33154	Building Review (Residential)	Electrical	Approved	1	Yes	02/27/2025	02/26/2025	03/19/2025
	MEP-2024-005294	9485 Harding Ave FI 33154	Electrical Trade Review	Electrical	In Review	2*	Yes		03/03/2025	03/17/2025
	MEP-2025-007067	9472 Harding Ave FI 33154	Electrical Trade Review	Electrical	Requires Re-submit	1	Yes	02/27/2025	02/24/2025	03/17/2025

## ALL REVIEWS BY DUE DATE BY DEPARTMENT (03/17/2025 TO 03/22/2025)

Reviewer	Permit Number /Plan Number	Address	Submittal	Review	Review Status	Version	Required	Complete Date	Assigned Date	Due Date
										<i>Comments: Pending proof of MDC fire approval</i>
	MEP-2025-007078	9450 Bay Dr FI 33154	Electrical Trade Review	Electrical	Approved	1	Yes	03/03/2025	02/25/2025	03/18/2025
	MEP-2025-007087	9450 Bay Dr FI 33154	Electrical Trade Review	Electrical	Approved	1	Yes	03/03/2025	02/26/2025	03/19/2025
	MEP-2025-007091	9526 Harding Ave FI 33154	Electrical Trade Review	Electrical	Approved	1	Yes	02/27/2025	02/26/2025	03/19/2025

**TOTAL REVIEWS FOR CANDELARIO MARTINEZ: 14**

**TOTAL REVIEWS FOR ELECTRICAL: 14**

### MECHANICAL

JAN PEREZ

Permit Reviews	2023-005089	9485 Harding Ave FI 33154	Mechanical Trade Review	Mechanical	Approved	2*	Yes	03/04/2025	03/04/2025	03/18/2025
	2024-006747-BR	8841 Garland Ave FI 33154	Building Review (Residential)	Mechanical	Requires Re-submit	2*	Yes	03/04/2025	03/03/2025	03/17/2025
	2025-006930-BR	9148 Carlyle Ave FI 33154	Building Review (Residential)	Mechanical	Approved	1	Yes	03/13/2025	02/25/2025	03/18/2025
	MEP-2025-007080	9450 Bay Dr FI 33154	Mechanical Trade Review	Mechanical	Approved	1	Yes	02/27/2025	02/25/2025	03/18/2025

**TOTAL REVIEWS FOR JAN PEREZ: 4**

**TOTAL REVIEWS FOR MECHANICAL: 4**

### PLANNING/ZONING

SCARLET HAMMONS

Permit Reviews	2024-005391	9040 Abbott Ave FI 33154	Building Review (Residential)	Planning/Zoning	In Review	1	Yes		03/06/2025	03/21/2025
	2024-006572-BC	8925 Collins Ave FI 33154	Building Review (Commercial)	Planning/Zoning	Approved	2*	Yes	03/14/2025	03/07/2025	03/21/2025
	2024-006604	9273 Byron Ave FI 33154	Pool Review	Planning/Zoning	In Review	2*	Yes		03/14/2025	03/21/2025
	2024-006723	300 Surfside Blvd FI 33154	Pool Review	Planning/Zoning	Pending Assignment	1	Yes		03/04/2025	03/18/2025
	2025-006882-BR	8835 Byron Ave FI 33154	Building Review (Residential)	Planning/Zoning	Approved	2*	Yes	02/26/2025	03/07/2025	03/21/2025
	2025-006957-BR	716 88 St FI 33154	Building Review (Residential)	Planning/Zoning	In Review	2*	Yes		03/05/2025	03/19/2025
	2025-007000-BC	9273 Collins Ave FI 33154	Building Review (Commercial)	Planning/Zoning	Approved	1	Yes	02/25/2025	02/25/2025	03/18/2025
	2025-007024-BR	301 88Th St FI 33154	Building Review (Residential)	Planning/Zoning	Approved	1	Yes	02/27/2025	02/25/2025	03/18/2025
	2025-007035-BC	9481 Harding Ave FI 33154	Building Review (Commercial)	Planning/Zoning	In Review	1	Yes		02/25/2025	03/18/2025
	2025-007084-BR	1380 Biscaya Dr FI 33154	Building Review (Residential)	Planning/Zoning	Approved	1	Yes	03/13/2025	02/26/2025	03/19/2025
	2025-007089-BR	1400 Biscaya Dr FI 33154	Building Review (Residential)	Planning/Zoning	Requires Re-submit	1	Yes	03/05/2025	02/26/2025	03/19/2025
										<i>Comments: Side setback must be 10ft from the property line that extends into the water body.</i>

## ALL REVIEWS BY DUE DATE BY DEPARTMENT (03/17/2025 TO 03/22/2025)

Reviewer	Permit Number /Plan Number	Address	Submittal	Review	Review Status	Version	Required	Complete Date	Assigned Date	Due Date
<b>TOTAL REVIEWS FOR SCARLET HAMMONS: 11</b>										
<b>TOTAL REVIEWS FOR PLANNING/ZONING: 11</b>										
<b>PLUMBING</b>										
<b>ROBERTO CONDE</b>										
Permit Reviews	2024-006568	8818 Hawthorne Ave FI 33154	Plumbing Trade Review	Plumbing	Approved	2*	Yes	03/17/2025	03/05/2025	03/19/2025
	2024-006604	9273 Byron Ave FI 33154	Pool Review	Plumbing	Pending Assignment	2*	Yes		03/14/2025	03/21/2025
	2024-006695	9073 Dickens Ave FI 33154	Plumbing Trade Review	Plumbing	Approved	3*	Yes	03/10/2025	03/07/2025	03/21/2025
	2024-006723	300 Surfside Blvd FI 33154	Pool Review	Plumbing	Approved	1	Yes	03/05/2025	03/04/2025	03/18/2025
								<i>Comments: WELL PERMIT REQUIRED. A WELL IS REQUIRED FOR THE DEWATERING PROCESS. DUMPING WATER ONTO PROPERTY OR TO A STORM DRAIN IS PROHIBITED...RC</i>		
	2025-006930-BR	9148 Carlyle Ave FI 33154	Building Review (Residential)	Plumbing	Requires Re-submit	1	Yes	03/03/2025	02/25/2025	03/18/2025
								<i>Comments: PROVIDE A SANITARY ISOMETRIC. PROVIDE WATER DISTRIBUTION ISOMETRIC. PROVIDE A SHOWER DETAIL WITH AND WITHOUT BENCHES. 120 GL. IN AC CLOSET. PLEASE CLARIFY. PROVIDE A DETAIL OF A ANTI CORROSIVE TYPE HANGER FOR PIPING UNDER THE SLAB.. NOTE ON PLANS: NO CELLULAR CORE PIPING BELOW ANY STRUCTURE..RC</i>		
	2025-007097	716 88 St FI 33154	Plumbing Trade Review	Plumbing	Requires Re-submit	1	Yes	03/03/2025	02/27/2025	03/20/2025
								<i>Comments: SCHLUTER SHOWER DETAIL NOTES NOT LEGIBLE, TOO SMALL, CANNOT READ NOTES. PROVIDE PLANS FOR REVIEW AS PER THE 2020 FBC BUILDING, 107.1, 107.2.1, SUBMITTAL OF DOCUMENTS. YOU ONLY PROVIDED ONE DETAIL. PROVIDE OTHER SHOWER DETAILS INCLUDING WATERPROOFING DETAILS WHERE THERE IS A WINDOW IN THE SHOWER.PROVIDE DETAILS FOR ALL SHOWERS ON THE SECOND FLOOR INCLUDING BENCHES. SHOW THE ENTIRE FLOOR AREA INCLUDING SHOWER DRAIN. ENGINEER OF RECORD TO SIGN AND SEAL PLUMBING REVISION .</i>		
	2025-007098	9165 Collins Ave FI 33154	Plumbing Trade Review	Plumbing	Approved	1	Yes	03/03/2025	02/27/2025	03/20/2025
	2025-007104-BC	9201 Collins Ave FI 33154	Building Review (Commercial)	Plumbing	Requires Re-submit	1	Yes	03/05/2025	02/28/2025	03/21/2025
								<i>Comments: 1. BUILDING REVIEW REQUIRED. 2. PROVIDE AN EXISTING FLOOR PLAN AND A PROPOSED FLOOR PLAN THAT COMPLIES WITH THE 2023 FBC BUILDING, 107.1 AND 107.2.1, SUBMITTAL OF DOCUMENTS.. 3. PROVIDE A DETAIL OF AN APPROVED FIRE RESISTANT ASSEMBLY FOR FLOOR PENETRATIONS AS PER THE 2023 FBC PLUMBING, 307.3, THRU PENETRATIONS, TUB BOX PENETRATION. 4. PROVIDE A SHOWER DETAIL THAT SHOWS THE SLOPE OF THE UNDERLAYMENT ON PLANS, 1/4 INCH PER FOOT. 5. NOTE ON PLANS: NEW SHOWER VALVE SHALL BE OF THE ANTI SCALD TYPE AND SHALL BE EQUIPPED WITH INTEGRAL STOPS.RC</i>		
	2025-007122	8705 Carlyle Ave FI 33154	Pool Review	Plumbing	Approved	1	Yes	03/05/2025	03/04/2025	03/18/2025
								<i>Comments: For pool pump, pool piping</i>		
	MEP-2025-007068	9472 Harding Ave FI 33154	Plumbing Trade Review	Plumbing	Requires Re-submit	1	Yes	02/26/2025	02/24/2025	03/17/2025

## ALL REVIEWS BY DUE DATE BY DEPARTMENT (03/17/2025 TO 03/22/2025)

Reviewer	Permit Number /Plan Number	Address	Submittal	Review	Review Status	Version	Required	Complete Date	Assigned Date	Due Date		
				<i>Comments: REVISION MISSING PLUMBING PERMIT APPLICATION....RC</i>								
	MEP-2025-007081	9450 Bay Dr FI 33154	Plumbing Trade Review	Plumbing	In Review	1	Yes		02/25/2025	03/18/2025		
	MEP-2025-007082	9450 Bay Dr FI 33154	Plumbing Trade Review	Plumbing	Approved	1	Yes	02/26/2025	02/26/2025	03/19/2025		
	MEP-2025-007086	9450 Bay Dr FI 33154	Plumbing Trade Review	Plumbing	Approved	1	Yes	02/26/2025	02/26/2025	03/19/2025		

TOTAL REVIEWS FOR ROBERTO CONDE: 13

**TOTAL REVIEWS FOR PLUMBING: 13**

### ROOF

#### ULISES FERNANDEZ

Permit Reviews	2025-007093-BR	9332 Bay Dr FI 33154	Roof Review	Roof	Requires Re-submit	1	Yes	03/13/2025	02/26/2025	03/19/2025
				<i>Comments: 1. SUBMITAL IS COMPLETE. 2. SHOW ALL LOCATION AND SIZES OF DRAINS AND OVER-FLOWS ON ROOF PLAN. 3. SHOW LOCATION AND DIMENSIONS OF ELEVATED PRESSURES ON ROOF PLAN. 4. SUBMIT ENTIRE PRODUCT APPROVAL. 4. SUBMIT WIND LOAD CALCULATIONS. 5. SUBMIT U.L. LISTING.</i>						
	2025-007102-BR	9108 Abbott Ave FI 33154	Roof Review	Roof	Approved	1	Yes	03/13/2025	02/28/2025	03/21/2025

TOTAL REVIEWS FOR ULISES FERNANDEZ: 2

**TOTAL REVIEWS FOR ROOF: 2**

### STRUCTURAL

#### STRUCTURAL REVIEWER

Permit Reviews	2024-006604	9273 Byron Ave FI 33154	Pool Review	Structural	In Review	2*	Yes		03/14/2025	03/21/2025
	2024-006723	300 Surfside Blvd FI 33154	Pool Review	Structural	Pending Assignment	1	Yes		03/04/2025	03/18/2025
	2024-006747-BR	8841 Garland Ave FI 33154	Building Review (Residential)	Structural	Approved	2*	Yes	03/07/2025	03/03/2025	03/17/2025
	2025-006930-BR	9148 Carlyle Ave FI 33154	Building Review (Residential)	Structural	Approved	1	Yes	03/07/2025	02/25/2025	03/18/2025
	2025-007035-BC	9481 Harding Ave FI 33154	Building Review (Commercial)	Structural	In Review	1	Yes		02/25/2025	03/18/2025
	2025-007105-BR	9009 Byron Ave FI 33154	Building Review (Residential)	Structural	In Review	1	Yes		02/28/2025	03/21/2025

TOTAL REVIEWS FOR STRUCTURAL REVIEWER: 6

**TOTAL REVIEWS FOR STRUCTURAL: 6**

**GRAND TOTAL OF ALL REVIEWS: 77**

*\* This review is a resubmittal*